

agrees to maintain and service certain heating, ventilating, and air conditioning equipment located at				
for		("Less		
	This Agreement shall include the maintenance and service of the fo	ollowing equipment:		
	Description of Equipment Make	Model Serial No.		
Said s	service and maintenance shall include the following:			
□ A.	 Fans and Blowers 1. Lubricate all moving parts as required. 2. Adjust tension on all belt drives and align when necessary. 	 H. Evaporate Condenser, Cooling Tower and Air Washer 1. Lubricate all motors and pumps and fan bearings. 2. Check pump packing. (Adjust or replace when required 		
□ в.	Filters	3. Check coil. (Scale or dirt)		
□ C.	 Clean or replace every days with Motors and Motor Controls Clean, oil, and/or grease. Check for overload under full operation. Check contactes contacts and clean as necessary. Check time clock for proper setting. 	 4. Check spray nozzles. (Clean and adjust when required 5. Check water strainer. (Clean when required) 6. Check pump strainer. (Clean when required) 7. Check float control. (Adjust when required) 8. Check drip pan and rain connections. 9. Check drive belts. (Align and adjust when required) 		
□ D.	 5. Check and adjust operation of all electric or pneumatic controls. Gas Furnaces Check combustion. Check and clean pilot. Check fan limit control. 	 Check rotation of fan. Check bleeder line. (Adjust when required) Check water valve setting. Adjust automatic controls. Drain and flush sump pan. 		
□ E.	 4. Check pilot safety device. 5. Check automatic gas valve. Boilers Check combustion. Check and clean pilot. Check fan limit control. Check pilot safety device. Check low water cut off. Check automatic water feeder. 	 I. Air Cooled Condensers Lubricate all motors and fan bearings as required. Check pump packing. Check coils. (Scale and dirt) Check air intake screen. (Clean when required) Check drip pan and drain connections. Check drive belts. (Align and adjust when required) Check rotation of fan. Adjust automatic controls. 		
	 Check water strainer. Check pressure regulator. Check relief valve. Drain and recharge expansion tank. Blow down boiler and controls. Check automatic gas valve. Check boiler control settings. Check steam valves and traps. Adjust controls as required. 	 J. Controls-Electric and/or Pneumatic Check thermostat contacts. Check starter contacts. Check damper motors. Air controls-drain water. Clean air compressor intake. Check air compressor oil. Check air compressor motor. Lubricate air compressor motor. 		
🗆 F.	Dampers (Automatic or Manual)	9. Spot check stats for calibration.		
	 Check and adjust for correct operation. Check all linkage and adjust where necessary. Check fire damper for fusible links. 	 K. Fin Coils (Water, Steam or Refrigerant) 1. Check for leaks. 2. Check strainers. 		
□G.	• • • • • • • • • • • • • • • • • • • •	3. Check coil face for dirt.		
	 Lubricate all bearings as required. Check oil level and pressure. Check head pressure. (Adjust if required) Check suction pressure. (Adjust if required) Check head bolts and anchor bolts. (Adjust if required) Check refrigerant charge. Test for leaks. 	 L. Pad Type Evaporative Coolers Oil and adjust all motors, bearings and drives as requir Adjust water distribution over pads. Check pads for dirt, looseness, sagging or disintegratio Flush sump and check for leaks. Adjust float. Oil and check pump and motor. 		

- 7. Test for leaks.
- PAGE 1 OF 2 STANDARD FORM SERVICE AGREEMENT

- 8. Check rotation.
- 9. Align and tighten belts.
- 10. Check amperage and voltage

- M. 1. Check Water Treatment Control
- N. Boiler Water Treatment

ADDITIONAL TERMS AND CONDITIONS

1. Lessee to receive 10% discount on repair parts.

2. Lessee to receive _____ % discount on labor.

3. Any alterations, additions, adjustments or repairs made by others, unless authorized or agreed upon by Contractor, will be cause to terminate this Agreement.

4. Repairs necessitated by fire, floods, acts of God, abuse or the improper use of equipment listed will be the sole responsibility of Lessee and are not covered by this Agreement.

5. This Agreement does not cover any work or changes which might at some future date be required by government regulations, or insurance company requirements.

6. While this Agreement covers all functional components of the air conditioning system, it does not cover ductwork, structural supports or other sheet metal components which may deteriorate due to corrosion or rust.

 NEITHER PARTY to this Agreement shall hold the other responsible for any indirect or consequential damage of a commercial nature such as, but limited to, loss of revenue or loss of use of any equipment or facilities.

8. Contractor's maximum liability based upon any claim or cause of action shall not exceed the yearly contract price of this Agreement.

9. Payment for this Agreement will be net upon receipt of invoice. Contractor reserves the right to discontinue service any time payments have not

been made as agreed so long as Contractor first gives at least 15 days prior written notice to Lessor. 10. This Agreement may be terminated by either party upon 30 days written notice to the other and to Lessor. A refund for the remaining contract period will be made on a prorata basis, with deduction for work already completed.

11. Lessee shall receive Priority Service.

The address for the billing of Lessee shall be:	BILLING ADDRESS	
The price for this service contract shall be \$	CONTRACT PRICE	
TERM to to		

CANCELLATION

In the event that this agreement is canceled or terminated, Contractor agrees to provide written notice of said cancellation or termination to Lessor at the address listed above.

Dated:	
	CONTRACTOR

Dated:

NOTE: These forms are often modified to meet changing requirements of law and needs of the industry. Always write or call to make sure you are utilizing the most current form: AIR COMMERCIAL REAL ESTATE ASSOCIATION, 700 S. Flower Street, Suite 600, Los Angeles, Calif. 90017

PAGE 2 OF 2 STANDARD FORM SERVICE AGREEMENT ©2000 - AIR COMMERCIAL REAL ESTATE ASSOCIATION